

CE2 Engineers, Inc.

Project Report

**Alaska Energy Authority
Rural Energy Group
Power Plant 4000 Gallon Storage Tank -
Code Compliance Work**

St. George, Alaska

Final Report

Period of:

June 24 to June 26, 2002

Report Date:

June 29, 2002

REPORT OVERVIEW

This report is intended to provide the Alaska Energy Authority Project Manager with an overview from the Construction Manager of the work completed on the St. George Power Plant 4000 Gallon Diesel Storage Tank.

PROJECT DESCRIPTION

The purpose of this project is to complete the work required to bring the Power Plant 4000 gallon diesel storage tank to Code Compliance.

NARRATIVE

Work Completed :

With reference to the attached photo's, the following items were completed:

- Identification and flow arrows installed
- Overhead piping support installed
- Pressure relief installed
- Cast steel locking valves installed

Impact to Budget, Schedule, and/or Project Quality:

- All work is complete and under the estimated budget.